

## AMEV attestation for certified BACnet devices

### 1. The following BACnet device is certified as per DIN EN ISO 16484-5:

Supplier	Fr. Sauter AG		
Product name	EY-modulo 5 Room Automation Controller		
Product model number	EY-RC504F001, EY-RC504F101, EY-RC504F202, EY-RC504F011,EY-RC504F021, EY-RC504F041, EY-RC504F0C1, EY-RC504F0D1, EY-RC505F031,EY-RC505F051, EY-RC505F061, EY-RC505F071, EY-RC505F081, EY-RC505F091,EY-RC505F0A1, EY-RC505F0B1, EY-RC505F0E1, EY-RC505F0F1, EY-RC505F0G1,EY-RC505F0H1, EY-RC505F0J1, EY-RC505F0K1		
Standard device profile	B-BC, B-LD, B-GW	BACnet protocol vers. / rev.	1.16
Firmware revision	V4.0.1b1722		

Data link layer options	<input checked="" type="checkbox"/> BACnet IP (Annex J)	<input type="checkbox"/> BACnet over LonTalk
	<input type="checkbox"/> BACnet MS/TP master	<input type="checkbox"/> BACnet MS/TP slave
	<input type="checkbox"/> MS/TP baud rates:	
	<input type="checkbox"/> PTP	
Static device binding	<input type="checkbox"/> Yes (for MS/TP only)	
Networking options	<input checked="" type="checkbox"/> BBMD	<input checked="" type="checkbox"/> Reg. by foreign device
	<input type="checkbox"/> Router, medium:	
Character set	<input checked="" type="checkbox"/> UTF-8	
Reporting options	<input checked="" type="checkbox"/> Intrinsic reporting	<input checked="" type="checkbox"/> Algorithmic reporting

### 2. The device supports BACnet functions as per AMEV profile:

<input type="checkbox"/> AMEV profile AS-A (Automation station, base version)	As of:
<input checked="" type="checkbox"/> AMEV profile AS-B (Automation station, extended version)	As of: AMEV BACnet 2017
<input type="checkbox"/> AMEV profile	As of:

### 3. Basis for AMEV attestation:

<input checked="" type="checkbox"/> Test report of test lab iHomeLab dated 14.02.2022 number 21.080.002.002
<input checked="" type="checkbox"/> AMEV recommendation BACnet 2017 As of: 01.08.2017 (see <a href="http://www.amev-online.de">www.amev-online.de</a> )

### 4. The AMEV attestation is only valid in combination with the certificate:

<input checked="" type="checkbox"/> Certificate number BTL-30832 (see <a href="http://www.bacnetinternational.net/btl/">http://www.bacnetinternational.net/btl/</a> )
---

Cologne, 24.03.2022



Dipl. Ing. (FH) Eike Hinck  
Gebäudewirtschaft der Stadt Köln  
Ottoplatz 1  
50678 Köln  
Germany  
Tel.: +49 221 – 221 23435  
Email: Eike.Hinck@stadt-koeln.de

(AMEV chairman BACnet)



# WSP CERT

Dr.-Ing. Frank Bitter  
Kapuzinerweg 7  
70374 Stuttgart  
Germany

(BACnet certification body)