

AMEV attestation for certified BACnet devices

1. The following BACnet device is certified as per DIN EN ISO 16484-5:

| | | | |
|-------------------------|---------------------------------|------------------------------|------|
| Supplier | Fr. Sauter AG | | |
| Product name | EY-modulo 6 Building Controller | | |
| Product model number | EY6AS60F011, EY6AS80F021 | | |
| Standard device profile | B-BC, B-LD | BACnet protocol vers. / rev. | 1.16 |
| Firmware revision | V1.2.2b1992 | | |

| | | |
|-------------------------|---|--|
| Data link layer options | <input checked="" type="checkbox"/> BACnet IP (Annex J) | <input type="checkbox"/> BACnet over LonTalk |
| | <input type="checkbox"/> BACnet MS/TP master | <input type="checkbox"/> BACnet MS/TP slave |
| | <input type="checkbox"/> MS/TP baud rates: | |
| | <input type="checkbox"/> PTP | |
| Static device binding | <input type="checkbox"/> Yes (for MS/TP only) | |
| Networking options | <input checked="" type="checkbox"/> BBMD | <input checked="" type="checkbox"/> Reg. by foreign device |
| | <input type="checkbox"/> Router, medium: | |
| Character set | <input checked="" type="checkbox"/> UTF-8 | |
| Reporting options | <input checked="" type="checkbox"/> Intrinsic reporting | <input checked="" type="checkbox"/> Algorithmic reporting |

2. The device supports BACnet functions as per AMEV profile:

| | |
|--|-------------------------|
| <input type="checkbox"/> AMEV profile AS-A (Automation station, base version) | As of: |
| <input checked="" type="checkbox"/> AMEV profile AS-B (Automation station, extended version) | As of: AMEV BACnet 2017 |
| <input type="checkbox"/> AMEV profile | As of: |

3. Basis for AMEV attestation:

| |
|---|
| <input checked="" type="checkbox"/> Test report of test lab MBS GmbH dated 17.12.2021 number VG 2021_1008723 |
| <input checked="" type="checkbox"/> AMEV recommendation BACnet 2017 As of: 01.08.2017 (see www.amev-online.de) |

4. The AMEV attestation is only valid in combination with the certificate:

| |
|---|
| <input checked="" type="checkbox"/> Certificate number BTL-30815 (see http://www.bacnetinternational.net/btl) |
|---|

Cologne, 10.02.2022

E. Hinck

Dipl. Ing. (FH) Eike Hinck
Gebäudewirtschaft der Stadt Köln
Ottoplatz 1
50678 Köln
Germany
Tel.: +49 221 – 221 23435
Email: Eike.Hinck@stadt-koeln.de

.....
(AMEV chairman BACnet)

F. Bitter

WSP
CERT
Dr.-Ing. Frank Bitter
Kapuzinerweg 7
70374 Stuttgart
Germany

.....
(BACnet certification body)